

LICENCE CERTIFICATE

for TÜV Rheinland Test Mark

No. 968/EZ 120.05/08

Licence holder:	OMRON Corporation Safety Standards Group Shiokoji Horikawa, Shimogyo-ku Kyoto 600-8530 Japan		
Manufacturer:	OMRON (Shanghai) Co., Ltd. Jinji Road 789 Jinqiao Export Processing District Pudong New Area Shanghai 201206 China		
Date of application:	File ref.:	Date of issue:	
2006-01-25	968/EZ 120.05/08	2008-11-07	
Devices:	Safety relay units of the G9SB series		Annual fee-units
Max. achievable safety category depending on the application (see User's Manual):	Safety category 4 for the types: G9SB-2002-A, G9SB-2002-C, G9SB-200-B, G9SB-200-D, G9SB-301-B, G9SB-301-D, G9SB-3012-A, G9SB-3012-C Safety category 3 for the type: G9SB-3010		
Stop category:	0 according the EN 60204-1 and EN ISO 13850		
Operating modes:	See User's Manual		
Rated voltage:	24 VDC for G9SB-3010 All other applications alternative 24 VDC/AC		
Outputs:	Contact outputs (contact ratings): AC 250 V/5 A/AC1, $\cos\phi = 1$ DC 30 V/5 A/DC1 AC 240 V/2 A/AC15 DC 24 V/1 A/DC13		
Annual fee:	for the G9SB series		4
The test sample	<input checked="" type="checkbox"/>	will be kept by TÜV Rheinland Industrie Service GmbH	
	<input type="checkbox"/>	will be kept by the licence holder for the disposal of TÜV Rheinland Industrie Service GmbH	
Special remarks: Report-No.: 968/EZ 120.05/08 and Certificate No. 968/EZ 120.05/08 dated 2008-11-07			

Test Mark:



The Licence for the using of the TÜV Rheinland Test Mark is only valid for the licence holder and can only be transferred from TÜV Rheinland Industrie Service GmbH to third persons.

The right for the using of the Test Mark is restricted to such products which are described and are examined by TÜV Rheinland Industrie Service GmbH appropriately.

This Licence certificate has to be given back to TÜV Rheinland Industrie Service GmbH if it is being declared as invalid.

Furthermore all clauses of the Test Mark Regulations apply.

TÜV Rheinland Industrie Service GmbH
Geschäftsfeld ASI
Automation, Software und Informationstechnologie
Am Grauen Stein, 51105 Köln
Postfach 91 09 51, 51101 Köln

2011-07-04
Date

Company stamp



Dipl.-Ing. Stephan Häb